

WATER TEST RESULTS - VARIOUS SOURCES

Updated 5/18/20

TESTING FOR	Coral Springs Improvement District	City of Coral Springs	Publix Bottled "Spring Water"	Zephyrhills Bottled Spring Water	Dasani Bottled Water	FIJI Bottled Water	Suggested Municipal Range
pH	8.10	9.00	6.95	7.58	5.95	7.4	(6.5-8.5)
Total Alkalinity	25	50	20	172	6	142	(20-60 ppm)
Total Hardness	40	70	22	188	18	120	(20-60 ppm)
Turbidity	0.06	0.07	0	0	0	0	(< 0.3 NTU)
Color	5.0	8.0	0.0	0.0	10.0	0.0	(< 15 ppm)
Total Chlorine Residual (disinfection)	2.9	2.1	0.1	0.01	0	0.1	(1.0-4.0 ppm)
Iron Content	0.01	0.01	0.01	0.01	0.04	0.27	(< 0.3 ppm)
Fluoride	0.74	0.52	0.15	0.04	0.06	0.15	(0.6-0.8 ppm)